



## VpCI™ ADDITIVES FOR FORMULATORS

# Boiler Lizard™ Patent Pending

## VpCI™ Boiler Lay-up



### PRODUCT DESCRIPTION

Cortec's Boiler Lizard™ contains Vapor phase Corrosion Inhibitor (VpCI™) powder in a polyvinyl alcohol (PVA) water-soluble bag. The powder formulation is free of phosphates, heavy metals, nitrites and free amines. Designed for dry lay-up of boilers, the Boiler Lizard™ powder protects metals in enclosed spaces. The VpCIs™ vaporize and adsorb on all metal surfaces, reaching all recessed areas and interior cavities.

### FEATURES

- Provides continuous corrosion protection during dry lay-up period
- Protects ferrous metals and aluminum
- Provides protection in the vapor phase (void), liquid phase and the interface
- Up to 12 months protection
- Vapor phase inhibiting action protects inaccessible and recessed surfaces
- Requires little or no surface preparation for routine shutdown maintenance
- VpCI layer does not need to be removed prior to equipment start-up

- Eliminates need for other forms of protection including nitrogen blankets, silica gel and hydrazine
- Reduces chemical consumption and costs
- Safe for handling
- Biodegradable, non-toxic and non-irritating PVA bags
- Increases worker productivity and safety
- Formulation is free of phosphate, heavy metals, nitrites and free amines
- Protects up to 1,000 gallons system capacity per bag (5 yd<sup>3</sup> or 3.8 m<sup>3</sup>)

### METHOD OF APPLICATION

Completely drain and cool boiler down. Remove and discard outer protective water insoluble bag. Place Boiler Lizard flat in boiler and slit open the inner water soluble bag to begin total corrosion protection. Slit this inner bag 2" (5 cm) from one end to 2" (5 cm) from the other end. Seal all openings to the boiler internals. No product or inner bag removal is required prior to boiler start-up. When the boiler is put back in service, fill with water and employ common start-up procedure. The inner PVA bag will dissolve.

### DIMENSIONS

Tube	3" D x 37" H (8 cm x 94 cm)
Bag	4" W x 34" H (10 cm x 86 cm)

### PHYSICAL PROPERTIES OF POWDER

Appearance	White to off-white powder
pH	6.5-6.9 (1% aqueous)
Melting Point	371°-398°F (188°-203°C)

### PACKAGING AND STORAGE

Boiler Lizards™ are supplied in carton tubes (1 bag per tube). Store in sealed container in a dry warehouse. Do not store in conditions above 130°F (54°C). Shelf life is 2 years.



**FOR INDUSTRIAL USE ONLY**  
**KEEP OUT OF REACH OF CHILDREN**  
**KEEP CONTAINER TIGHTLY CLOSED**  
**NOT FOR INTERNAL CONSUMPTION**  
**CONSULT MATERIAL SAFETY DATA SHEET FOR MORE INFORMATION**

**LIMITED WARRANTY**

All statements, technical information and recommendations contained herein are based on tests Cortec Corporation believes to be reliable, but the accuracy or completeness thereof is not guaranteed.

Cortec Corporation warrants Cortec® products will be free from defects when shipped to customer. Cortec Corporation's obligation under this warranty shall be limited to replacement of product that proves to be defective. To obtain replacement product under this warranty, the customer must notify Cortec Corporation of the claimed defect within six months after shipment of product to customer. All freight charges for replacement products shall be paid by customer.

Cortec Corporation shall have no liability for any injury, loss or damage arising out of the use of or the inability to use the products.

**BEFORE USING, USER SHALL DETERMINE THE SUITABILITY OF THE PRODUCT FOR ITS INTENDED USE, AND USER ASSUMES ALL RISK AND LIABILITY WHATSOEVER IN CONNECTION THEREWITH.** No representation or recommendation not contained herein shall have any force or effect unless in a written document signed by an officer of Cortec Corporation.

**THE FOREGOING WARRANTY IS EXCLUSIVE AND IN LIEU OF ALL OTHER WARRANTIES, EXPRESS, IMPLIED OR STATUTORY, INCLUDING WITHOUT LIMITATION ANY IMPLIED WARRANTY OF MERCHANTABILITY OR OF FITNESS FOR A PARTICULAR PURPOSE. IN NO CASE SHALL CORTEC CORPORATION BE LIABLE FOR INCIDENTAL OR CONSEQUENTIAL DAMAGES.**



4119 White Bear Parkway, St. Paul, MN 55110 USA  
 Phone (651) 429-1100, Fax (651) 429-1122  
 Toll Free (800) 4-CORTEC, E-mail [info@cortecvc.com](mailto:info@cortecvc.com)  
 Internet <http://www.CortecVpCI.com>

printed on recycled paper 10% post consumer

Revised 11/14/02. Cortec Corporation 2000-2002. All rights reserved. Supersedes: 01/31/02. VpCI™ and Boiler Lizard™ are trademarks of Cortec Corporation.

Distributed by:



**OTiK Sp. z o.o.**  
 ul. Hutnicza 4  
 81-061 Gdynia  
 tel.: 58 6230498  
 fax: 58 6230496  
[otik@use.pl](mailto:otik@use.pl)  
[www.inhibitory.use.pl](http://www.inhibitory.use.pl)



Certificate No.70781

Certificate No.81867